

**RADON INSPECTION
The Amity High School
503 Oak Street
Amity, Oregon 97101**

Prepared For:

**Steve Park, Maintenance Supervisor
Amity School District SD 4J
807 S. Trade Street
Amity, Oregon 97101**

EIS Job No. 2019060.High school radon

Prepared By:

**Charles A. Spear
Environmental Professional
AHERA Certification #IR-19-2439A
Environmental Inspection Services
11981 Fargo Road
Aurora, Oregon 97002
Cell # (503) 680-6398
E MAIL: charles_a_spear@yahoo.com**

Charles A. Spear

Charles A. Spear, Environmental Professional

August 24, 2019



EIS

ENVIRONMENTAL INSPECTION SERVICES



TABLE OF CONTENTS

<u>DESCRIPTION</u>	<u>PAGE NO.</u>
1.0 EXECUTIVE SUMMARY.....	1-2
2.0 RADON ENVIRONMENTAL RISK	3
3.0 RADON DESCRIPTION	3
4.0 RADON CHARACTERISTICS	3
5.0 RADON TESTING ACTIVITY	4-5
6.0 RADON TEST RESULT TABLE	6
7.0 RADON RISK ASSESSMENT	7
8.0 RADON LABORATORY ANALYSIS	7-8
9.0 RECOMMENDATIONS & CONCLUSIONS	8-9
10.0 LIMITATIONS	9

APPENDIX 1.0
RADON ANALYTICAL TEST RESULTS

APPENDIX 2.0
CHAIN'S OF CUSTODY (COC'S)

APPENDIX 3.0
AMITY SCHOOL SAMPLING FLOOR PLAN

APPENDIX 4.0
RADON REGULATION

APPENDIX 5.0
CONSULTANT RESUME

1.0 EXECUTIVE SUMMARY

August 24, 2019

EIS JOB No. 2019060.Amity High School radon

Steve Park, Maintenance Supervisor
Amity School District Sd 4J
807 S. Trade Street
Amity, Oregon 97101

RE: Short term radon testing of The Amity High School
building located at 503 Oak Street in Amity, Oregon
97101

Dear Mr. Park,

This letter summarizes the finding of a short term (48-hour) radon sampling test episode conducted at the subject school property improvements between Friday, August 9, 2019 and Monday, August 12, 2019. The radon sampling episode was conducted by Charles A. Spear, field representative of Environmental Inspection Services (EIS) with no custodian escort through the entire Amity High school building. Elevated radon considerations exceeding 4 pCi/L were analytically confirmed in five (5) specific functional areas of the school described as the Multi-purpose room, Room 201B, 200B, and the Band/Drama rooms based on the short term simultaneous test results of the fifty-one (51) detached samplers.

In the opinion of EIS, additional short term radon retesting is required at the Amity SD 4J High School building in the band/drama areas and the multi-purpose room. EIS noted additional radon measurement requirements for the Amity SD 4J High school building functional areas described as the band/dram room, band support rooms No.s 200B and 201B and the multi-purpose rooms based on the analytical test results. Radon concentration levels have been noted to vary from school to school and also from room to room.

The following five (5) frequently occupied rooms require additional testing.

<u>Sample serial No.</u>	<u>Sample location</u>	<u>Sample test result</u>
4806979	Multi-purpose	5.9 pCi/L
4798196	Room 201B	4.3 pCi/L
4806995	Band/Drama	7.1 pCi/L
4774431	Band/Drama	6.5 pCi/L
4798350	Room 200B	6.4 pCi/L

(Refer to the sample table of Section 6 for details concerning the elevated test results). Additional short term testing is required at this time based on these analytical radon test results.

The subject school improvements are collectively referred to as the Amity-SD 4J High School building located at 503 Oak Street in Amity, Oregon. Five() of the short term radon test results exceeded the EPA radon concentration action limit of 4 pCi/L. Radon concentrations varied between a low measurement of 0.4 pCi/L and a single highest radon concentration measurement of 7.1 pCi/L. A total of eighteen (18) radon tester analytical results were at or below 1.0 pCi/L.

Elevated radon considerations were noted for the High school band/drama support classrooms based on the short term simultaneous test results of the fifty-one (51) detached samplers. The average radon concentration for the Amity High school is 1.70 pCi/L and the average national indoor radon concentration is 1.3 pCi/L. The EPA notes there is no safe level of radon. If there are questions concerning the radon testing at the district please initially contact the Amity school district administration authority.



Charles Arthur Spear
Environmental Professional

2.0 RADON ENVIRONMENTAL RISK

The U.S. Environmental Protection Agency (EPA) and other major national and international scientific organizations have concluded that radon is a human carcinogen and poses a serious environmental health problem. The EPA recommends that schools take action to reduce the level of radon concentration levels are 4 pCi/L or higher. The EPA notes there is no safe level of radon.

The U.S. surgeon general has warned about the health risk from the exposure to radon in indoor air. The surgeon general has urged Americans to test their homes because radon is the leading cause of lung cancer for non-smokers in the United States and breathing in radon over prolonged periods can present a significant health risk. The USEPA has estimated that approximately 21,000 lung cancer-related deaths occur annually with an estimated 275 lung cancer deaths annually in Oregon.

3.0 RADON DESCRIPTION

Radon gas is an extremely toxic, chemically inert, odorless, colorless, and tasteless naturally-occurring radioactive element having the symbol Rn. Radon has the atomic number 86; an atomic weight of 222; a melting point of -71 degrees Celsius; a boiling point of -62 degrees; and 18 radioactive isotopes. It is derived from the radioactive decay of radium and is used in cancer treatment; as a tracer in leak detection; and in radiology.

4.0 RADON CHARACTERISTICS

The concentrations of radon in a building are dependent on factors to include the concentration of uranium and radium in the soil; the type of underlying geology; soil permeability; available migration pathways such as subsurface utilities; foundation openings; air temperature and pressure differentials and building ventilation.

Radon may migrate into a study area by either a pressure driven transport or no pressure differentials. The subject school was built on concrete foundation and slab on slab foundations. Radon may migrate through foundations by the availability of expansion joints and cracks in the foundation. Radon may also migrate into a building through basements, utility trenches, pipe runs, HVAC systems, and other building ventilation systems. Radon contributions from building materials off-gassing are not often the source of measurable radon.

5.0 RADON TESTING ACTIVITY

A total of fifty-one (51) short term radon test units were placed throughout the district high school building frequently occupied areas to include the classrooms, locker rooms, shops, gymnasiums, music room, band room, cafeteria, kitchen, offices, work rooms, and library. The radon samplers were opened on Friday, August 9, 2019 and capped on Monday, August 12, 2019. Radon test results were reported to EIS on Thursday, August 15, 2019.

Radon measurements varied between a low radon measurement of 0.4 pCi/L to one high measurement of 7.1 pCi/L. Elevated radon considerations were noted for five (5) test units based on these short term simultaneous test results. A total of eighteen (18) radon tester results were at or below 1.0 pCi/L.

LOWER RADON CONCENTRATIONS

The lowest radon concentrations at or below 1.0 pCi/L were detected in a total of eighteen (18) samplers. The lowest eighteen (18) analytical test results are listed as follows:

<u>Sample serial No.</u>	<u>Sample location</u>	<u>Sample test result</u>
4802310	Wood shop	0.8 pCi/L
4809207	Gymnasium	0.6 pCi/L
4768679	Gymnasium	0.9 pCi/L
4801869	Gymnasium	0.7 pCi/L
4801859	Gymnasium	0.8 pCi/L
4801886	Gymnasium	0.8 pCi/L
4802319	Gymnasium	0.6 pCi/L
4801729	Gymnasium	0.9 pCi/L
4806989	Room 401W	0.8 pCi/L
4768758	Library	0.7 pCi/L
466885	Library	0.6 pCi/L
4801812	Room 19A	0.5 pCi/L
4802383	Room 19B	0.8 pCi/L
4801814	Room 19C	0.8 pCi/L
4801904	SAT	0.6 pCi/L
4774417	Room 103	1.0 pCi/L
4774401	Room 202	0.4 pCi/L
4774505	Room 100 dup	0.9 pCi/L

MODERATE RADON MEASUREMENTS

Radon measurements at/or between 3.0 pCi/L and 4.0 pCi/L are noted as areas approaching four (4) picocuries per liter (pCi/L). This result was analytically confirmed in one (1) of the short term radon samplers. The single radon sampler with a radon concentrations approaching the action limit of 4 pCi/L is summarized as follows;

<u>Sample serial No.</u>	<u>Sample location</u>	<u>Sample test result</u>
2802068	Room 212	3.3 pCi/L

ELEVATED RADON MEASUREMENTS

A total of five (5) short term samplers concentrations exceeded 4.0 pCi/L. A total of three (3) radon sampler areas exceeding the EPA action limit of 4 pCi/L are noted as radon retest areas. The Band/Drama area of the building is of particular interest for the purposes of this evaluation. The five samplers exceeding the EPA listed radon action limit of 4 pCi/L are listed as follows. The areas are summarized as follows:

<u>Radon Serial No.</u>	<u>Location</u>	<u>Result</u>
4806979	Multi-purpose	5.9 pCi/L
4798196	Room 201B	4.3 pCi/L
4806995	Band/Drama	7.1 pCi/L
4774431	Band/Drama	6.5 pCi/L
4798350	Room 200B	6.4 pCi/L

Four of these test units represent test areas of the band/drama area of the school. All the passive radon samplers were placed in the center and at the edges the all the test areas away from walls, windows, and doors to include the band/drama rooms, classrooms, gymnasiums, library, cafeteria, offices, and administration support rooms. The capped radon samplers were packaged; logged on a chain of custody form; and shipped to ProLab Laboratories.

6.0 RADON TEST RESULTS SUMMARY TABLE

The radon sample concentrations for the Amity High School building varied between a low concentration of 0.5 pCi/L and a single high analytical radon concentration of 7.1 pCi/L. The analytical test results for tester concentrations exceeding 3.0 pCi/L are all summarized as follows:

<u>Sample serial No.</u>	<u>Sample location</u>	<u>Sample test result</u>
2802068	Room 212	3.3 pCi/L

ELEVATED RADON MEASUREMENTS

A total of five (5) short term samplers concentrations exceeded 4.0 pCi/L. A total of three (3) radon sampler areas exceeding the EPA action limit of 4 pCi/L are noted as radon retest areas. The Band/Drama area of the building is of particular interest for the purposes of this evaluation. The five samplers exceeding the EPA listed radon action limit of 4 pCi/L are listed as follows. The areas are summarized as follows:

<u>Radon Serial No.</u>	<u>Location</u>	<u>Result</u>
4806979	Multi-purpose	5.9 pCi/L
4798196	Room 201B	4.3 pCi/L
4806995	Band/Drama	7.1 pCi/L
4774431	Band/Drama	6.5 pCi/L
4798350	Room 200B	6.4 pCi/L

EIS noted additional radon measurement requirements for the Amity SD 4J High school building functional areas described as the multi-purpose room, the band support rooms of 200B and 201B, and the band/drama room based on the analytical test results. Radon concentration levels have been noted to vary from school to school and also from room to room. All frequently occupied rooms in contact with the ground require testing. This radon sampling episode noted the following;

Total number of testers - fifty-one(51)
High reading - Five(5) above 4 pCi/L
Low reading - Eighteen (18) less than 1.0 pCi/L

7.0 RADON MEASUREMENT RISK ASSESSMENT

The average Amity High school building radon concentration reading is 1.70 pCi/L with analytical test results varying from a radon low concentration measurement of 0.4 pCi/L at one tester location to one (1) high concentration measurements of 7.1 pCi/L at a single location. Additional short term test radon testing is recommended for the Amity High School building at this time based on the radon short term analytical test results.

The U.S. surgeon general has warned about the health risk from the exposure to radon in indoor air. The surgeon general has urged Americans to test their homes because radon is the leading cause of lung cancer for non-smokers in the United States and breathing in radon over prolonged periods can present a significant health risk. The USEPA has estimated that approximately 21,000 lung cancer-related deaths occur annually with an estimated 275 lung cancer deaths annually in Oregon.

8.0 RADON LABORATORY ANALYSIS

The radon was measured at the Pro-Lab Laboratory located at 1675 North Commerce Parkway in Weston, Florida using the liquid scintillation Method (EPA 402-R-92-004). The selected radon sampler devices utilized at the Amity SD 4J High school building is described as passive activated charcoal adsorption devices (AC).

The short term testers utilize activated carbon to absorb the radon gas in the air. The test unit has activated carbon with a perforation screen to filter out radon decay products. The absorber is resealed by EIS and shipped to Pro-Lab for processing and evaluation. The selected passive radon tester devices do not uniformly adsorb radon during the testing episode and are not described as integrating devices.

The total of fifty-one (51) radon test units supplied by a certified laboratory known as Pro-lab. The testers were placed within functional administration areas of the Amity administrative areas between Friday, August 9, 2019 and Monday, August 12, 2019. The total of fifty-one (51) short term samplers were capped and submitted to Pro-lab laboratories for radon analysis on Monday, August 12, 2019 and received by the Pro-Lab laboratories on Thursday, April 15, 2019. Radon test results were reported to EIS on Monday, August 19, 2019.

Radon measurement levels varied from a low concentration of 0.4 pCi/L at one (1) test position to the highest radon concentration reading of 7.1 pCi/L. Five (5) elevated radon concentrations exceeding 4 pCi/l were analytically detected in the Amity High school building samplers.

9.0 RECOMMENDATIONS & CONCLUSIONS

In the opinion of EIS, additional short term radon retesting is required at the Amity SD 4J High School building in the band/drama areas and the multi-purpose room. EIS noted additional radon measurement requirements for the Amity SD 4J High school building functional areas described as the band/dram room, band support rooms No.s 200B and 201B and the multi-purpose rooms based on the analytical test results. Radon concentration levels have been noted to vary from school to school and also from room to room. The following five (5) frequently occupied rooms require additional testing.

<u>Sample serial No.</u>	<u>Sample location</u>	<u>Sample test result</u>
4806979	Multi-purpose	5.9 pCi/L
4798196	Room 201B	4.3 pCi/L
4806995	Band/Drama	7.1 pCi/L
4774431	Band/Drama	6.5 pCi/L
4798350	Room 200B	6.4 pCi/L

In the opinion of EIS, the satisfactory radon test results are generally indicative of generally satisfactory radon conditions in most functional classrooms, cafeteria, library, gymnasium, common rooms, offices, and administrative support rooms and other student and staff occupied spaces of the subject building with the aforementioned five exceptions.

The additional favorable retesting of the five areas described in this section of the report will conclude the short term testing requirements at the Amity High School at this time. Persistent short term measurements exceeding 4 pCi/L would prompt a recommendation for long term testing in any functional areas with detections of persistent radon concentrations exceeding 4 pCi/L.

In the opinion of EIS, based on actual extensive passive radon testing at the subject building additional limited short term radon retesting is recommended in five (5) areas of the Amity SD 4J High School Building at this time. The sample analytical position and result tables are listed in Appendix 2.0 of this report. Actual radon analytical test results are included as listed in Appendix 2.0 of this report. If there any questions please contact the Amity District Administration Office.

Respectfully,


Charles A. Spear
Environmental Professional

10.0 LIMITATIONS

This report was prepared in accordance with generally accepted ASTM standards of environmental practice at the time this investigation was performed. Evaluations of the conditions at the site for the purpose of this investigation are made from a limited number of observation points and may be subjective in some cases. The client is solely responsible for providing any notices or disclosures to concerned public agencies or to the public.

Environmental Inspection Services has prepared this report based on information collected from available analytical test results. The scope of this investigation is limited and did include a limited number of radon testers and no subsurface or sub-slab radon screening of soil and groundwater. No radon mitigation was performed on the subject property.

This report is not a substitution for a formal radon mitigation and/or radon mitigation effort. The findings and conclusions are not to be regarded as scientific certainties. Findings are based on professional judgement concerning independent laboratory data significance. This report is an expression of professional opinion and is not a warranty expressed or implied.

APPENDIX 1.0
RADON ANALYTICAL TEST RESULTS

ENVIROMENTAL INSPECTION SERVICES

11981 FARGO RD NE
AURORA, OR 97002
503.680.6398

charles_a_spear@yahoo.com

AMITY HIGH SCHOOL
503 OAK ST. AMITY, OR 97101

Vial #	Location	Start Date	Start Time	End Date	End Time	LEVEL
4806971	MULTI-P	8/9/2019	8:41AM	8/12/2019	10:10AM	1.2
4806979	MULTI-P	8/9/2019	8:41AM	8/12/2019	10:10AM	5.9
4801937	MULTI-P	8/9/2019	8:41AM	8/12/2019	10:10AM	1.3
4802081	KITCHEN	8/9/2019	8:41AM	8/12/2019	10:33AM	1.1
4802310	WOOD	8/9/2019	8:46AM	8/12/2019	10:15AM	0.8
4768684	WOOD OF	8/9/2019	8:47AM	8/12/2019	10:15AM	1.1
4802180	RM 217	8/9/2019	8:47AM	8/12/2019	10:15AM	1.1
4801766	RM 218	8/9/2019	8:48AM	8/12/2019	10:15AM	2.4
4801920	SHOP	8/9/2019	8:50AM	8/12/2019	10:18AM	1.3
4768727	SHOP	8/9/2019	8:51AM	8/12/2019	10:18AM	1.5
4802213	215	8/9/2019	8:53AM	8/12/2019	10:18AM	2.3
4768693	214	8/9/2019	8:53AM	8/12/2019	10:25AM	2.3
4802226	213	8/9/2019	8:54AM	8/12/2019	10:28AM	1.5
4802068	212	8/9/2019	8:55AM	8/12/2019	10:28AM	3.3
4809207	GYM	8/9/2019	9:01AM	8/12/2019	10:25AM	0.6
4768679	GYM	8/9/2019	9:01AM	8/12/2019	10:25AM	0.9
4801869	GYM	8/9/2019	9:01AM	8/12/2019	10:25AM	0.7
4801859	GYM	8/9/2019	9:03AM	8/12/2019	10:28AM	0.8
4806989	401 W	8/9/2019	9:07AM	8/12/2019	10:28AM	0.8
4802302	401 S	8/9/2019	9:07AM	8/12/2019	10:28AM	0.6
4802072	COACH	8/9/2019	9:10AM	8/12/2019	10:25AM	1.2
4801822	114 A-B	8/9/2019	9:13AM	8/12/2019	10:25AM	1.1
4801886	GYM	8/9/2019	9:15AM	8/12/2019	10:25AM	0.8
4802319	GYM	8/9/2019	9:15AM	8/12/2019	10:25AM	0.6
4801729	GYM	8/9/2019	9:15AM	8/12/2019	10:25AM	0.9
4802377	GYM	8/9/2019	9:15AM	8/12/2019		
4802203	108	8/9/2019	9:20AM	8/12/2019	10:25AM	1.7
4802281	108 T	8/9/2019	9:23AM	8/12/2019	10:25AM	2.1
4768809	RM 107	8/9/2019	9:24AM	8/12/2019	10:25AM	1.6
4768758	LIBRARY	8/9/2019	9:30AM	8/12/2019	10:35AM	0.7
466885	LIBRARY	8/9/2019	9:33AM	8/12/2019	10:35AM	0.6
4801812	19A	8/9/2019	9:35AM	8/12/2019	10:35AM	0.5
4802383	19B	8/9/2019	9:35AM	8/12/2019	10:35AM	0.8
4801814	19C	8/9/2019	9:35AM	8/12/2019	10:35AM	0.8
4801904	SAT	8/9/2019	9:35AM	8/12/2019	10:40AM	0.6
4801847	LOCKERS	8/9/2019	9:40AM	8/12/2019	10:40AM	1.1
4802374	LOCKERS	8/9/2019	9:40AM	8/12/2019	10:35AM	1.0
4798296	RT OFF	8/9/2019	9:47AM	8/12/2019	10:35AM	2.0
4801941	201 A	8/9/2019	9:48AM	8/12/2019	10:35AM	2.9
4798196	201 B	8/9/2019	9:48AM	8/12/2019	10:25AM	4.3
4801819	201 C	8/9/2019	9:50AM	8/12/2019	10:25AM	2.4
4774401	202	8/9/2019	9:55AM	8/12/2019	10:25AM	0.4
4768871	RM 105	8/9/2019	9:58AM	8/12/2019	10:25AM	1.3
4802198	18 A	8/9/2019	10:00AM	8/12/2019	10:25AM	1.3
4774417	RM 103	8/9/2019	10:01AM	8/12/2019	10:30AM	1.0
4802290	RM 104	8/9/2019	10:03AM	8/12/2019	10:30AM	1.3
4774435	RM 100	8/9/2019	10:05AM	8/12/2019	10:35AM	1.1
4774505	RM 100 DUP	8/9/2019	10:05AM	8/12/2019	10:35AM	0.9
4798393	RM 102	8/9/2019	10:06AM	8/12/2019	10:35AM	1.3
4806995	BAND/DRAMA	8/9/2019	10:15AM	8/12/2019	10:35AM	7.1
4774431	BAND/DRAMA	8/9/2019	10:15AM	8/12/2019	10:35AM	6.5
4798350	200 B	8/9/2019	10:16AM	8/12/2019	10:35AM	6.4

TOTAL
HIGH
LOW
AVG
TESTERS - 51
LOSTER - 7.1
TESTER - 0.4
- 1.70 pCi/L

TESTERS EXCEEDING 2.5 pCi/L - 7
TESTERS LESS THAN 1.0 pCi/L - 18
EXCEEDING 4.0 pCi/L - 5

TEST ID NUMBER: 1250073
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4802180	1ST FLOOR RM 217	Aug 09, 2019 8:47 AM	Aug 12, 2019 10:15 AM	Aug 16, 2019 4:38 AM	1.1 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PC/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L, you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS

NRPP CERT# 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARI.0028
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1250107
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4768809	1ST FLOOR RM 107	Aug 09, 2019 9:24 AM	Aug 12, 2019 10:21 AM	Aug 16, 2019 12:54 AM	1.6 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PC/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS

NRPP CERT# 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1250106
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4802281	1ST FLOOR 108	Aug 09, 2019 9:23 AM	Aug 12, 2019 10:25 AM	Aug 16, 2019 1:59 AM	2.1 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PC/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS

NRPP CERT# 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1250105
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4802203	1ST FLOOR 108	Aug 09, 2019 9:20 AM	Aug 12, 2019 10:25 AM	Aug 16, 2019 1:48 AM	1.7 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PC/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

LIMITATIONS OF DATA AND PRODUCT LIABILITY


PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS

NRPP CERT# 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1250105
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4802203	1ST FLOOR 108	Aug 09, 2019 9:20 AM	Aug 12, 2019 10:25 AM	Aug 16, 2019 1:48 AM	1.7 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

LIMITATIONS OF DATA AND PRODUCT LIABILITY


PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS

NRPP CERT# 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1250103
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4801729	1ST FLOOR GYM	Aug 09, 2019 9:15 AM	Aug 12, 2019 10:25 AM	Aug 16, 2019 4:06 AM	0.9 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PC/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS

NRPP CERT# 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1250102
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4802319	1ST FLOOR GYM	Aug 09, 2019 9:15 AM	Aug 12, 2019 10:25 AM	Aug 16, 2019 4:16 AM	0.6 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PC/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

LIMITATIONS OF DATA AND PRODUCT LIABILITY


PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS

NRPP CERT# 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1250098
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4801886	1ST FLOOR GYM	Aug 09, 2019 9:15 AM	Aug 12, 2019 10:25 AM	Aug 16, 2019 5:42 AM	0.8 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS

NRPP CERT# 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1250097
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4801822	1ST FLOOR 114 A-B	Aug 09, 2019 9:13 AM	Aug 12, 2019 10:25 AM	Aug 16, 2019 5:53 AM	1.1 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PC/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.

LIMITATIONS OF DATA AND PRODUCT LIABILITY


PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS

NRPP CERT# 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1250096
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4802072	1ST FLOOR COACH	Aug 09, 2019 9:10 AM	Aug 12, 2019 10:25 AM	Aug 16, 2019 6:04 AM	1.2 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PC/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS

NRPP CERT# 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1250095
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4802302	1ST FLOOR 401 (S)	Aug 09, 2019 9:07 AM	Aug 12, 2019 10:28 AM	Aug 16, 2019 6:15 AM	0.6 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PC/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS

NRPP CERT# 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1250093
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4806989	1ST FLOOR 401 (W)	Aug 09, 2019 9:07 AM	Aug 12, 2019 10:28 AM	Aug 16, 2019 6:25 AM	0.8 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PC/L) OR HIGHER. Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS

NRPP CERT# 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARI.0028
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1250090
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4801859	1ST FLOOR GYM	Aug 09, 2019 9:03 AM	Aug 12, 2019 10:25 AM	Aug 16, 2019 6:36 AM	0.8 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PC/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.

LIMITATIONS OF DATA AND PRODUCT LIABILITY


PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS

NRPP CERT# 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1250089
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4801869	1ST FLOOR GYM	Aug 09, 2019 9:01 AM	Aug 12, 2019 10:25 AM	Aug 16, 2019 6:47 AM	0.7 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PC/L) OR HIGHER. Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS

NRPP CERT# 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1250087
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4768679	1ST FLOOR GYM	Aug 09, 2019 9:01 AM	Aug 12, 2019 10:25 AM	Aug 16, 2019 6:58 AM	0.9 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS

NRPP CERT# 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1250086
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4809207	1ST FLOOR GYM	Aug 09, 2019 9:01 AM	Aug 12, 2019 10:25 AM	Aug 16, 2019 7:08 AM	0.6 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PC/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS

NRPP CERT# 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1250084
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4802068	1ST FLOOR 212	Aug 09, 2019 8:55 AM	Aug 12, 2019 10:28 AM	Aug 16, 2019 7:19 AM	3.3 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS

NRPP CERT# 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARI.0028
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1250082
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4802226	1ST FLOOR 213	Aug 09, 2019 8:54 AM	Aug 12, 2019 10:28 AM	Aug 15, 2019 11:49 PM	1.5 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PC/L) OR HIGHER. Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS

NRPP CERT# 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1250081
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4768693	1ST FLOOR 214	Aug 09, 2019 8:53 AM	Aug 12, 2019 10:25 AM	Aug 15, 2019 11:59 PM	2.3 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER. Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

LIMITATIONS OF DATA AND PRODUCT LIABILITY


PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS

NRPP CERT# 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1250079
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4802213	1ST FLOOR 215	Aug 09, 2019 8:53 AM	Aug 12, 2019 10:18 AM	Aug 16, 2019 3:35 AM	2.3 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS

NRPP CERT# 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1250078
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4768727	1ST FLOOR SHOP	Aug 09, 2019 8:51 AM	Aug 12, 2019 10:18 AM	Aug 16, 2019 3:46 AM	1.5 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PC/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS

NRPP CERT# 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1250077
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4801920	1ST FLOOR SHOP	Aug 09, 2019 8:50 AM	Aug 12, 2019 10:18 AM	Aug 16, 2019 3:57 AM	1.3 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS

NRPP CERT# 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1250074
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4801766	1ST FLOOR RM 218	Aug 09, 2019 8:48 AM	Aug 12, 2019 10:15 AM	Aug 16, 2019 4:27 AM	2.4 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER. Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L, you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS

NRPP CERT# 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1250071
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4768684	1ST FLOOR WOOD	Aug 09, 2019 8:47 AM	Aug 12, 2019 10:15 AM	Aug 16, 2019 4:49 AM	1.1 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PC/L) OR HIGHER. Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

LIMITATIONS OF DATA AND PRODUCT LIABILITY


PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS

NRPP CERT# 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARI.0028
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1250069
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS


<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4802310	1ST FLOOR WOOD	Aug 09, 2019 8:46 AM	Aug 12, 2019 10:45 AM	Aug 16, 2019 4:59 AM	0.8 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS

NRPP CERT# 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARI.0028
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1250068
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4802081	1ST FLOOR KITCHEN	Aug 09, 2019 8:41 AM	Aug 12, 2019 10:33 AM	Aug 16, 2019 5:10 AM	1.1 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS

NRPP CERT# 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1250066
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4801937	1ST FLOOR MULTI-P	Aug 09, 2019 8:41 AM	Aug 12, 2019 10:10 AM	Aug 16, 2019 5:21 AM	1.3 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (pCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS

NRPP CERT# 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1250065
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4806979	1ST FLOOR MULTI-P	Aug 09, 2019 8:41 AM	Aug 12, 2019 10:10 AM	Aug 16, 2019 5:32 AM	5.9 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS

NRPP CERT# 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1250063
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4806971	1ST FLOOR MULTI-P	Aug 09, 2019 8:41 AM	Aug 12, 2019 10:10 AM	Aug 16, 2019 1:26 AM	1.2 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS

NRPP CERT# 109347 RT
NRSB CERT # 188S007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1250061
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4798350	1ST FLOOR 200 B	Aug 09, 2019 10:15 AM	Aug 12, 2019 10:35 AM	Aug 16, 2019 1:37 AM	6.4 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS

NRPP CERT# 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1250059
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4774431	1ST FLOOR BAND/DRAMA	Aug 09, 2019 10:15 AM	Aug 12, 2019 10:35 AM	Aug 16, 2019 1:48 AM	6.5 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PC/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.

LIMITATIONS OF DATA AND PRODUCT LIABILITY


PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS

NRPP CERT# 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARI0028
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1250054
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4806995	1ST FLOOR BAND/DRAMA	Aug 09, 2019 10:15 AM	Aug 12, 2019 10:35 AM	Aug 16, 2019 1:58 AM	7.1 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS

NRPP CERT# 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1250052
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4798393	1ST FLOOR RM 102	Aug 09, 2019 10:06 AM	Aug 12, 2019 10:35 AM	Aug 16, 2019 2:09 AM	1.3 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PC/L) OR HIGHER. Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS

NRPP CERT# 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1250051
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4774505	1ST FLOOR RM 100 DUP	Aug 09, 2019 10:05 AM	Aug 12, 2019 10:35 AM	Aug 16, 2019 2:20 AM	0.9 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PC/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.

LIMITATIONS OF DATA AND PRODUCT LIABILITY


PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS

NRPP CERT# 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1250047
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4774435	1ST FLOOR RM 100	Aug 09, 2019 10:05 AM	Aug 12, 2019 10:35 AM	Aug 16, 2019 2:31 AM	1.1 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER. Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS

NRPP CERT# 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1250046
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4802290	1ST FLOOR RM 104	Aug 09, 2019 10:03 AM	Aug 12, 2019 10:30 AM	Aug 16, 2019 2:41 AM	1.3 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (pCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS

NRPP CERT# 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AI



James E. McDonnell IV

TEST ID NUMBER: 1250044
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4774417	1ST FLOOR RM 103	Aug 09, 2019 10:01 AM	Aug 12, 2019 10:30 AM	Aug 16, 2019 2:52 AM	1.0 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PC/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS

NRPP CERT# 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1250043
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4802198	1ST FLOOR 18 A	Aug 09, 2019 10:00 AM	Aug 12, 2019 10:25 AM	Aug 16, 2019 3:03 AM	1.3 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PC/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS

NRPP CERT# 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1250042
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4768871	1ST FLOOR RM 105	Aug 09, 2019 9:58 AM	Aug 12, 2019 10:25 AM	Aug 16, 2019 3:14 AM	1.3 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PC/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

LIMITATIONS OF DATA AND PRODUCT LIABILITY


PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS

NRPP CERT# 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1250042
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4768871	1ST FLOOR RM 105	Aug 09, 2019 9:58 AM	Aug 12, 2019 10:25 AM	Aug 16, 2019 3:14 AM	1.3 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PC/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS
NRPP CERT# 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARI.0028
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1250041
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4774401	1ST FLOOR 202	Aug 09, 2019 9:55 AM	Aug 12, 2019 10:25 AM	Aug 16, 2019 3:24 AM	0.4 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER. Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS

NRPP CERT# 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1250040
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4801819	1ST FLOOR 201 C	Aug 09, 2019 9:50 AM	Aug 12, 2019 10:25 AM	Aug 16, 2019 3:37 AM	2.4 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PC/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**


LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS
NRPP CERT# 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1250039
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4798196	1ST FLOOR 201 B	Aug 09, 2019 9:48 AM	Aug 12, 2019 10:25 AM	Aug 16, 2019 3:48 AM	4.3 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PC/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

LIMITATIONS OF DATA AND PRODUCT LIABILITY


PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS

NRPP CERT# 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1250037
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4801941	1ST FLOOR 201 A	Aug 09, 2019 9:48 AM	Aug 12, 2019 10:35 AM	Aug 16, 2019 3:59 AM	2.9 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PC/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS
NRPP CERT# 109347 RT
NRSB CERT # 18SS007



James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL

TEST ID NUMBER: 1250036
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4798296	1ST FLOOR RT OFF	Aug 09, 2019 9:47 AM	Aug 12, 2019 10:35 AM	Aug 15, 2019 11:49 PM	2.0 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PC/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS

NRPP CERT# 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1250035
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4802374	1ST FLOOR LOCKERS	Aug 09, 2019 9:40 AM	Aug 12, 2019 10:35 AM	Aug 16, 2019 12:00 AM	1.0 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PC/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L, you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS

NRPP CERT# 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1250031
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4801847	1ST FLOOR LOCKERS	Aug 09, 2019 9:40 AM	Aug 12, 2019 10:40 AM	Aug 16, 2019 12:11 AM	1.1 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PC/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS

NRPP CERT# 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARI.0028
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1250030
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4801904	1ST FLOOR SAT	Aug 09, 2019 9:35 AM	Aug 12, 2019 10:40 AM	Aug 16, 2019 12:22 AM	0.6 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PC/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS

NRPP CERT# 109347 RT
NRSB CERT # 188S007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1250028
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4801814	1ST FLOOR 19C	Aug 09, 2019 9:35 AM	Aug 12, 2019 10:35 AM	Aug 16, 2019 12:32 AM	0.8 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PC/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS

NRPP CERT# 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARI.0028
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1250025
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4801812	1ST FLOOR 19A	Aug 09, 2019 9:35 AM	Aug 12, 2019 10:35 AM	Aug 16, 2019 12:54 AM	0.5 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

LIMITATIONS OF DATA AND PRODUCT LIABILITY


PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS

NRPP CERT# 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1250023
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4768885	1ST FLOOR LIBRARY	Aug 09, 2019 9:35 AM	Aug 12, 2019 10:35 AM	Aug 16, 2019 1:05 AM	0.6 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS

NRPP CERT# 109347 RT
NRSB CERT # 18SS007

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1250021
DATE RECEIVED: 08/15/2019
REPORT DATE: 08/19/2019

ENVIRONMENTAL INSPECTION SERVICE, INC.
11981 FARGO ROAD NORTHEAST,
AURORA, OR 97002

TEST LOCATION
AMITY HIGH SCHOOL
503 OAK ST
YAMHILL COUNTY
AMITY, OR 97101

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4768758	1ST FLOOR LIBRARY	Aug 09, 2019 9:30 AM	Aug 12, 2019 10:35 AM	Aug 16, 2019 1:15 AM	0.7 pCi/L

THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER. Please read the EPA Citizen's Guide to Radon at www.epa.gov/radon/pubs/citguide.html. Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Jose Figueroa, RMS

NRPP CERT# 109347 RT
NRSB CERT # 18SS007



James E. McDonnell IV

PRO-LAB NRSB # ARL0028
PRO-LAB NEHA ID # 101461AL

APPENDIX 2.0
CHAIN'S OF CUSTODY (COC'S)

RADON TEST CHAIN OF CUSTODY

CLIENT Environmental Inspection Services
11981 Fairway Road
Amity, Oregon 97002

SCHOOL (Name) Amity (High School)
 (Address) 503 Oak St.
Amity, Oregon 97001

Serial No. Location Start Date Cap off time Stop Date Cap On Time Result

4806971	Mult-r	8/9/19	8:41	8/12/19	10:10am	
4806979	Mult-r		8:41		10:10am	
4801937	Mult-r		8:41		10:10am	
4802081	Kitchen		8:41		10:33	
4802310	wood		8:46		10:45	
4768684	wood		8:47		10:15	
4802180	RM 217		8:47		10:15	
4801766	RM 218		8:48		10:15	
4801920	SHED		8:50		10:18	
4768727	SHED		8:51		10:18	
4802213	215		8:53		10:18	
4768693	214		8:53		10:25	
4802226	213		8:54		10:28	
4802068	212		8:55		10:28	
4809207	gym		9:01		10:25	
4768679	gym		9:01		10:25	
4801819	gym		9:01		10:25	
4801859	gym		9:03		10:25	
4806989	401 (w)		9:07		10:28	
4802302	401 (s)		9:07		10:28	
4802072	coach		9:10		10:25	
4801822	114 A-D		9:13		10:25	
4801886	gym		9:15		10:25	
4802359	gym		9:15		10:25	
4801729	gym		9:15		10:25	
4802377	gym		9:15		10:25	
4802203	108		9:20		10:25	
4802281	108+		9:23		10:25	
4768809	RM 107		9:24		10:21	

RADON TEST CHAIN OF CUSTODY


CLIENT Environmental Tugedion Services
11981 Fargo Road
Aurora, Oregon 97002

SCHOOL (Name) Aurora High School (High)
(Address) 503 Oak St.
Aurora, Oregon 97001

Serial No.	Location	Start Date	Cap off time	Stop Date	Cap On Time	Result
------------	----------	------------	--------------	-----------	-------------	--------

[illegible]

APPENDIX 3.0
AMITY SCHOOL SAMPLING FLOOR PLAN



APPENDIX 4.0
RADON REGULATION



Managing Radon in Schools

The *Indoor Air Quality Tools for Schools* Approach: Key Drivers and Strategies for Success

Successful school IAQ management programs are works in progress, and most districts put the components of success in place over time. The “Framework for Effective School IAQ Management: Key Drivers” is a system enhanced by continuous reinforcement. Implementation of one Key Driver will support and contribute to the development of another.

Strategies that support the Key Drivers complement this positive feedback loop. Overall program efficacy increases as school districts incorporate each Key Driver into their programs. This document describes how the “Framework for Effective School IAQ Management: Key Drivers” displayed in the graphic can help schools address radon risks as part of a comprehensive IAQ management program.

Successful IAQ management in schools comprises effective pollution source control. Radon — a radioactive gas — is one of the most hazardous indoor pollutants. Radon is the leading cause of lung cancer among non-smokers. In the U.S., an estimated 20,000 people die from radon-induced lung cancer annually. Thousands of classrooms nationwide have elevated radon levels, needlessly exposing hundreds of thousands of students and staff to this serious health risk.

EPA recommends testing all schools for radon. As part of an effective IAQ management program, schools can take simple steps to test for radon and reduce risks to occupants if high radon levels are found. The only way to know if elevated radon levels are present is to test. Many schools have successfully applied radon mitigation strategies to control indoor radon levels.

Radon gas enters from the soil beneath the school through cracks and openings in the foundation. Air pressure inside a building is sometimes lower than pressure in the soil under the foundation. Because of this difference in pressure, a building acts like a vacuum, drawing radon inside from the soil. Typical cracks and openings include joints where the floor meets the wall, expansion joints in the floor, openings in the floor for pipes and wires, and hollow masonry walls that penetrate the floor.

EPA offers detailed guidance on radon testing, results interpretation and mitigation in schools. Also, the *IAQ Design Tools for Schools* document provides guidance on how to control radon in renovation and construction projects and how to manage radon risks during repair, renovation and maintenance of existing facilities.

Framework for Effective School IAQ Management





EPA

Managing Radon in Schools

Key Drivers for Success & St

Organize for Success

Secure Senior Buy-In

Ensure senior-level support. Encourage administrators and facilities managers to connect with radon professionals to share their stories and solicit advice. Partner with parent groups, local health departments, facilities and maintenance organizations and other credible organizations to build understanding, trust and support.

Develop a Systematic Approach

Use the *IAQ Tools for Schools* Action Kit to tie your goals for radon testing to your overarching IAQ, health and environmental program goals. Coordinate this effort with existing IAQ management program activities.

Build an Effective Team

Assemble a multidisciplinary team to plan for radon testing and mitigation. Include on your team a trained radon professional; start by talking with your state radon program representative. Invite members from existing IAQ or Health and Safety Committees, facilities managers, air-conditioning technicians, IAQ professionals, school administrators, other staff and parents.

Design Standard Operating Procedures, or SOPs

Develop district-wide radon management procedures and adapt testing protocols and remedial action steps according to the needs of each school.

Organize
for Success

Act

to Address Structural,
Institutional and
Behavioral Issues

Communicate with Everyone All the Time

Make the Radon Program Meaningful

Include radon awareness as part of your overall IAQ management training and education efforts. Share with parents and staff the link between radon and building operations, and encourage them to test their homes as the home is often the most significant source of radon exposure.

Be Transparent and Inclusive

Communicate your action plan to stakeholders and the importance of radon testing. Share your testing results, mitigation plans and follow-up testing plans. In cases of elevated radon levels, ensure that your mitigation plan is in place so you can communicate those plans to parents. Invite key stakeholders to examine the issue and be part of the solution.

Communicate
with Everyone
All the Time

Plan

Your Short- and
Long-Term
Activities

Assess Your Environments Continuously



Links and Resources

<http://www.epa.gov/radon> — Visit EPA's Radon home page for facts, discussion points, and frequently asked questions and answers.

<http://www.epa.gov/radon/pubs> — Visit this webpage for EPA's radon guidance for schools.

<http://www.epa.gov/radon/whereyoulive.html> — Call your state radon office for state-specific recommendations.

<http://www.epa.gov/radon/radonleaders.html> — Connect with radon professionals and solicit advice.

<http://www.sosradon.org> — View the National Radon Poster Contest announcement and rules.

<http://www.epa.gov/iaq/schooldesign> — View the *IAQ Design Tools for Schools* document.

<http://www.epa.gov/iaq/schools/actionkit.html> — Order or print an *IAQ Tools for Schools* kit.



2017 ORS 332.345¹

Tests of schools for elevated levels of radon

- plan
- results

- (1) A school district shall develop a plan for testing schools for elevated levels of radon. At a minimum, plans developed under this subsection must:
 - (a) Provide for the testing of radon in any frequently occupied room in contact with the ground or located above a basement or a crawlspace; **and**
 - (b) Provide for the testing of radon in a school at least once every 10 years.
- (2) The Oregon Health Authority shall develop model plans for school districts to follow in implementing the requirements of this section. The authority shall seek the input of the Oregon School Boards Association in developing the model plans.
- (3) Results of a test performed under this section must be:
 - (a) Provided to the district school board;
 - (b) Provided to the authority in a manner prescribed by the authority; **and**
 - (c) Made readily available to parents, guardians, students, school employees, school volunteers, administrators and community representatives at the school's office or school district's office or on a website for the school or school district.
- (4) Information provided and made available under subsection (3) of this section must include the level of radon at which the United States Environmental Protection Agency recommends schools take action to reduce indoor radon concentrations. [Formerly 332.167]

Note: Section 3, chapter 729, Oregon Laws 2015, provides:

Sec. 3. (1) A school district shall submit the plan developed under section 2 of this 2015 Act [332.345 (Tests of schools for elevated levels of radon)] to the Oregon Health Authority on or before September 1, 2016.

- (2) Notwithstanding section 2 (1)(b) of this 2015 Act, plans developed under section 2 of this 2015 Act shall require initial testing of schools for elevated levels of radon on or before January 1, 2021.
- (3) Subsection (2) of this section does not apply to any school that has been tested for elevated

APPENDIX 5.0
CONSULTANT RESUME

RESUME

CHARLES ARTHUR SPEAR

**CERTIFIED ENVIRONMENTAL CONSULTANT (CEC)
ENVIRONMENTAL ASSESSMENT ASSOCIATION**

**REGISTERED ENVIRONMENTAL ASSESSOR
(Former) REA - 01241**

AHERA INSPECTOR (EPA CERTIFICATION NO. IR-19-2439A

**CERTIFIED ENVIRONMENTAL INSPECTOR
CEI - 10364**

Professional Background

Charles A. Spear, President and founder of Environmental Inspection Services has over 30 years technical experience ranging from facility food technologist to hazardous waste site remediation at Federal SUPERFUND sites from California to Maryland. Mr. Spear has successfully performed over 3,000 Phase One, Phase Two, and Phase Three Environmental Site Assessment inspections on properties from California to Alaska and east to Maryland. Mr. Spear has managed such projects as spilled mustard gas and organophosphate demilitarization and remediation as a decontamination sergeant of the U.S.Army Chemical Corps Technical Escort Unit Drill & Transfer Unit at Umatilla Army Depot and removal of leaking solvent underground storage tanks in California and Oregon. Additional experience included supervision as a USARMY NBC Specialist of focused remediation at the Federal Superfund site known as Aberdeen Proving Grounds, Maryland (Michaelsville Landfill). EIS does not conduct or perform geological work. Geologic work is referred to a state registered geologist.

Specifically, Mr. Spear has worked with clients such as: Housing & Urban Development, the International Fabric Care Industry (IFI), the U.S. Environmental Protection Agency, The U.S. Department of Defense, The Oregon Department of Environmental Quality (ODEQ), The Oregon Department of Forestry, INTEL, Sun Microsystems, IBM, Rohm & Haas, General Electric, AT&T, Texaco, Unocal, BP, Lockheed Missile and Space Center, FMC Corporation, Oregon Department of Fish & Wildlife, Washington Department of Fish & Wildlife, City of Beaverton, City of Hillsboro, City of Corvallis, Housing Authority of Portland, Northwest Oregon Housing Authority, Washington County Department of Housing, Housing & Urban Development, numerous lenders and mortgage companies, many private development and site remedial site projects, and many attorneys and investors.

Mr. Spear managed complex solvent tank farm removals at Xidex Corporation in Sunnyvale, California and was the site cleanup manager at the Rose City Plating Site currently developed as the Oregon Convention Center. Mr. Spear is a certified hazardous waste professional who has coupled military experience as a Nuclear, Biological and Chemical Specialist (U.S. Army MOS 54E20) with experience as a professional industrial and process research engineer in both the corrugated paper and petroleum industries.

Mr. Spear has managed food industry quality control as an inplant food technologist and prepared cost reduction programs as a corrugated boxboard industrial engineer in Dallas, Texas. He is currently registered with the states of California, Washington, and Oregon and is an active member of the national respected Environmental Assessment Association. Due diligence projects have been performed throughout the United States from Fairbanks, Alaska to San Diego, California.

Professional experience includes the following:

Professional Experience

- * Dry Cleaner Inspections
- * Environmental Consultation
- * Waste Reduction Audits
- * Regulatory Compliance Audits
- * Drum Yard Clearances
- * Tank Farm Removals/Replacements
- * Lab Packaging & Supervision
- * Environmental Site Assessments
- * Superfund Site Remediation
- * Hazardous Waste site Project Design & Management
- * Habitat/Wetlands Restoration
- * AHERA asbestos inspections for school districts
- * Landfill Remediation
- * Agricultural assessments
- * Indoor air quality inspections

Professional Employment/Consultation

- * C.F.S. Continental Coffee, Inc., Food technologist, Chicago, Illinois
- * Holiday Industries, Research Engineer, Grand Prairie, Texas
- * Alton Packaging Corporation, Industrial Engineer, Dallas, Texas
- * U.S. Army Chemical Corps., Nuclear, Biological, Chemical Specialist - Special assignment - Umatilla Army Depot (DATS)
Oregon and permanent assignment U.S. Army Chemical Corps. Technical Escort Unit in Edgewood, Maryland

- * Rollins Environmental Services, Remedial Project Manager
- * Crown Environmental Services, Technical Director, Redmond, California
- * Dames & Moore, Remedial design Engineer, Portland, Oregon
- * Pegasus Environmental Management Services, Director of Technical Services
- * Pacific Tank & Construction, Manager of Estimation, Portland, Oregon
- * Enviro-Logic Inc., Director of Environmental Site Assessment Division
- * Environmental Inspection Services Founder / President

Professional Education

- * American Standard for Testing & Materials ASTM E1527-13 Training
- * Bachelor of Science, Chemistry, Northeastern Illinois University, 1978
- * U.S. Army Chemical School, Ft. McClellan, Alabama, 1983
- * U.S. Army Technical Escort Unit, Accident / Incident Response Training Center 1983
- * Registered Environmental Assessor REA - 01241 (Former classification)
- * Certified environmental Inspector CEI - 10364
- * AHERA Certified Asbestos Inspector IR-19-2439A
- * ODEQ Soil Matrix Assessor & UST Decommission Supervisor ID No. 10305
- * Washington DOE Registered Environmental Assessor
- * Wetland Specialist - Training Wetlands Institute 1997
- * EPA / HUD Lead-Based Paint (LBP) Certified Inspector & Risk Assessor

Additional Education

- * Joint Military Material Packaging & Transportation
- * Asbestos Abatement Seminar attendance 1987
- * Thin Layer Chromatography, 1989
- * Oregon Registered Underground storage Tank Supervisor, 1998
- * Oregon Registered Soil Matrix Assessor, 1998
- * Washington Registered Assessor, 1991
- * Washington Registered Underground Storage Tank Supervisor, 1991
- * Wetland Training Institute Delineation Course Study University of Portland March 1997
- * 40-Hour HAZMAT Certified
- * AHERA-Certified Inspector

Special Skills

- * Facility Environmental Compliance Audits
- * ASTM standard Environmental Site Assessments
- * Computer Programming
- * Organic surfactant chemical synthesis and analysis
- * Hazardous Waste Site remediation/ estimating/ standards development
- * Design of filtration systems, batch and continuous process optimization studies
- * QA/QC Procedures
- * SUPERFUND Site Management
- * Industrial/ Research Engineering
- * Hazardous Waste Site Remediation/ Consultation
- * Wetlands Delineation and Habitat Restoration

Certification

- * U.S. Army MOS 54E20 - U.S. Army Chemical Corps.
- * International Fire Code Institute (IFCI) Certified UST Supervisor
- * International Fire Code Institute (IFCI) Certified Soil Matrix Assessor
- * Certified Hazardous Waste Manager
- * 40-hour OSHA Training
- * 40-hour OSHA Supervisor Training
- * Registered Environmental Assessor (DOE)
- * DEQ Registered UST Supervisor
- * DEQ Registered Soil Matrix Assessor
- * Resolution Trust Corporation (RTC) approved Environmental Assessor
- * California Registered Environmental Assessor (REA-01241)- program discontinued
- * Department of Ecology (DOE) Registered Environmental Assessor
- * Environmental Assessment Association, Certified Environmental Inspector & Transaction Specialist (CEI-10364)
- * Environmental Assessment Association, Certified Environmental Consultant (CEC)
- * AHERA Certified Asbestos Inspector
- * Wetland Delineator Graduate Wetland Training Institute, University of Portland 1997
- * EPA / HUD LBP Inspector & Risk Assessor
- * ASTM Training class, May, 2004